



wöhner

eta

Short circuit tests technical file Wöhner bar systems mounted on ETA enclosure

This file was drafted on November 11, 2004, and includes:

- 1) Technical report on the calculation methods extrapolated from the systems tested at CESI and assembly drawing (2 pages plus cover)*
- 2) Tables with chart of I_{cw} (I_{cc}) values and relative centerline distance between the supports, for the configuration of bar distribution system, 60 mm CL distance (11 pages plus cover)*
- 3) CESI test report No. A4/519182 (9 pages plus cover)*



wöhner

eta

Part 1)

Technical report and assembly drawing (2 pages)



wöhner

eta

The short circuit test is prescribed by standard EN 60439-1 Art. 8.2.3.

Such test is mandatory both for TTA and for PTТА assembly, whereby the difference is that, for ANS assembly, the standard only prescribes to refer to a tested type assembly, which is not necessarily stored and available at the assembly manufacturer.

From the test results, you can extrapolate the values for a bar system different from the tested one, adopting the procedure described in IEC publication 1117 (1992). "Method for the determination of short circuit resistance for non-standard switchgear and controlgear assemblies (PTТА)".

Standard EN 60439-1 in Note 1 to Art. 8.2.3.2.5 allows the extrapolation procedure according to the IEC publication 1117.

The actual calculation mode (formulas etc.) is given in the publication IEC 865, from which the harmonized standard EN 60865-1 has been extracted.

To allow an assembly manufacturer to develop a suitable and certifiable bar configuration, Wöhner has applied to Cesi to carry out a type test for short-circuit withstand strength on the following five bar distribution systems, mounted on the **ETA** enclosure model **ARETA** (two columns 800 x 2000 x 600, combined - see drawing):

- Triple T copper bars- In 2500 A *
- Double T copper bars- In 1600 A *
- Double T copper bars- In 1250 A *
- Copper bars 30 x 10 (mm) - In 630A/800 A *
- Copper bars 20 x 5 (mm) - In 320 A *

From the test value, all other I_{cw} (I_{cc}) values were extrapolated according to the CL distance between supports. For the following 6 systems - that complete the Wöhner range - all values were extrapolated from the two tested systems measuring 30 x 10 and 20 x 5, referring to the most suitable in terms of acceptable short circuit current, as prescribed by the standards.

- Copper bars 20 x 10 (mm) - In 520 A *
- Copper bars 12 x 10 (mm) - In 360 A *
- Copper bars 30 x 5 (mm) - In 450 A *
- Copper bars 25 x 5 (mm) - In 400 A *
- Copper bars 15 x 5 (mm) - In 250 A *
- Copper bars 12 x 5 (mm) - In 200 A *

(* - Refer to the catalog for effective capacity in A)




The 11 tables and related charts (see Section 2) indicate, for each system, the admitted values of short-lasting nominal current **I_{cw}** (without protection devices), or conditioned short circuit nominal current **I_{cc}** (conditioned by protection devices), the related peak current **I_{pk}** and the corresponding CL distance between supports. **Carefully read the notes in the tables for correct dimensioning.**

It must be underlined that standard defines two basic conditions:

1. **Short circuit current can be changed only with lower values**
2. **It is not allowed to change the support material or shape (only for the bar system)**

NOTE: The bar systems and the enclosure must be mounted in conformity with the manufacturers' prescriptions to ensure a mechanical resistance of components equivalent to the tested system, with particular reference to the screw locking torque and the fastening method for the bottom plate of the panel, which can be used as an alternative to crosspieces.

The ETA enclosure has withstood the short circuit dynamic stress with no problem, including short circuit between phase and earth, whereby current flows through the metal structure. The ARETA enclosures has already been tested with traditional bar systems up to 60 kA three-phase and 48 kA phase-earth, with no damage (see general catalog 2005/2006 and QuadroPlan manual), so they can be used up to these values with all the bar systems from the leading brands.



ETA-VÖHNER Prove di corto circuito Assieme		Disegnato da Verificato da Controllato da Autografo Data Foglio	Stato Firma Data Firma Data Firma
Per informazioni generali vedere il catalogo di riferimento ITA 01/01/01		Verificato da Controllato da Autografo Data Foglio	Stato Firma Data Firma Data Firma
La ETA S.p.A. si riserva ogni diritto di proprietà sul presente disegno		Data Foglio	Stato Firma Data Firma Data Firma



wöhner

eta

Part 2)
Tables with chart of l_{cw} (l_{cc}) values
and relative centerline distance between the supports,
for the configuration of bar distribution system,
60 mm CL distance
(11 pages)



wöhner



60 mm system

Triple T copper bars - In 2500 A (tested system)

Bar part number: 01 187; 01 227

Support part number: 01 232

Support CL distance (mm)	I _{cw} (kA for 1s)	I _{pk} (kA)
--------------------------	-----------------------------	----------------------

450	50	105
-----	----	-----

Test values

500	47	99
-----	----	----

550	44	92
-----	----	----


600	41	86
-----	----	----

650	38,5	81
-----	------	----

700	36,5	77
-----	------	----

Values extrapolated by calculation. NB All values in the table, also test values, are valid for 2 or 4 and more supports mounted at equal distances. For 3 supports at equal distances, decrease the CL value by 15% approx. or the I_{cw} value by 10% approx. (calculations according to EN 60865-1)

Triple T copper bars - In 2500 A





wöhner



60 mm system

Double T copper bars - In 1600 A (tested system)

Bar part number: 01 608; 01 190; 01 249; 01 229

Support part number: 01 231

Support CL distance (mm)	I _{cw} (kA for 1s)	I _{pk} (kA)
--------------------------	-----------------------------	----------------------

450	50	105
-----	----	-----

Test values

500	47	99
-----	----	----

550	44	92
-----	----	----


600	41	86
-----	----	----

650	38,5	81
-----	------	----

700	36,5	77
-----	------	----

Values extrapolated by calculation. NB All values in the table, also test values, are valid for 2 or 4 and more supports mounted at equal distances. For 3 supports at equal distances, decrease the CL value by 15% approx. or the I_{cw} value by 10% approx. (calculations according to EN 60865-1)

Double T copper bars - In 1600 A





wöhner

eta

60 mm system

Double T copper bars - In 1250 A (tested system)

Bar part number: 01 609; 01 224; 01 250; 01 223

Support part number: 01 231

Support CL distance (mm)	I _{cw} (kA for 1s)	I _{pk} (kA)
--------------------------	-----------------------------	----------------------

375	50	105
-----	----	-----

Test values

400	48	101
-----	----	-----

450	45,4	95
-----	------	----

500	43,5	91
-----	------	----

550	40,2	84
-----	------	----


600	37,5	79
-----	------	----

650	35,4	74
-----	------	----

700	33,5	70
-----	------	----

Values extrapolated by calculation. NB All values in the table, also test values, are valid for 2 or 4 and more supports mounted at equal distances. For 3 supports at equal distances, decrease the CL value by 15% approx. or the I_{cw} value by 10% approx. (calculations according to EN 60865-1)

Double T copper bars - In 1250 A






wöhner

eta

60 mm system

30 x 10 (mm) copper bars - In 630A/800A (tested system)			
Bar part number: 01 625; 01 204			
Support part number: 01 495			
Support CL distance (mm)	Icw (kA for 1s)	Ipk (kA)	
250	30	63	
300	27	57	
350	25	53	
400	23,8	50	
450	22,4	47	Values extrapolated by calculation. NB All values in the table, also test values, are valid for any number of supports (calculations according to standard EN 60865-1).
500	21	44	
550	20,2	40	

30 x 10 (mm) copper bars - In 630A/800A





wöhner



60 mm system

20 x 10 (mm) copper bars - In 520 A

Bar part number: 01 624


Support part number: 01 495

Support CL distance (mm)	I _{cw} (kA for 1s)	I _{pk} (kA)
--------------------------	-----------------------------	----------------------

250	30	63
300	27	57
350	25	53
400	23,5	50
450	21,5	45
500	20,2	42
550	19,5	39

All values were extrapolated through calculation from the values of the 30x10 tested system and are valid for any number of supports (calculations according to standard EN 60865-1).

20 x 10 (mm) copper bars - In 520 A





wöhner

eta

60 mm system

12 x 10 (mm) copper bars - In 360 A

Bar part number: 01 623


Support part number: 01 495

Support CL distance (mm)	I _{cc} (kA for 1s)	I _{pk} (kA)
250	24	50
300	24	50
350	24	50
400	22	46
450	20	40
500	13,5	27
550	12	24

All values were extrapolated through calculation from the values of the 30x10 tested system and are valid for any number of supports (calculations according to standard EN 60865-1).

NOTE: The I_{cc} value of 24 kA is the limit value calculated for the thermal effects of a failure lasting 1s and not for the mechanical resistance of copper. The calculation proves that such value can be maintained up to a 350 mm CL distance between the supports.

12 x 10 (mm) copper bars - In 360 A





wöhner

eta

60 mm system

30 x 5 (mm) copper bars - In 450 A

Bar part number: 01 622


Support part number: 01 495

Support CL distance (mm)	I _{cw} (kA for 1s)	I _{pk} (kA)
--------------------------	-----------------------------	----------------------

250	30	63
300	27	57
350	25	53
400	23,5	49
450	22,4	47
500	21	44
550	20	40

All values were extrapolated through calculation from the values of the 30x10 tested system and are valid for any number of supports (calculations according to standard EN 60865-1).

30 x 5 (mm) copper bars - In 450 A





wöhner



60 mm system

25 x 5 (mm) copper bars - In 400 A

Bar part number: 01 621


Support part number: 01 495

Support CL distance (mm)	I _{cw} (kA for 1s)	I _{pk} (kA)
250	25	53
300	25	53
350	25	53
400	23,5	49
450	22	46
500	20,5	43
550	19,5	39

All values were extrapolated through calculation from the values of the 30x10 tested system and are valid for any number of supports (calculations according to standard EN 60865-1).

NOTE: The I_{cw} value of 25 kA is the limit value calculated for the thermal effects of a failure lasting 1s and not for the mechanical resistance of copper. The calculation proves that such value can be maintained up to a 350 mm CL distance between the supports.

25 x 5 (mm) copper bars - In 400 A






wöhner

eta

60 mm system

20 x 5 (mm) copper bars - In 320 A (tested system)				
Bar part number: 01 620				
Support part number: 01 495				
Support CL distance (mm)	I _{cw} (kA for 1s)	I _{pk} (kA)		
200	20	40	Test values	
250	20	40	NOTE: The I _{cw} value of 20 kA is the limit value calculated for the thermal effects of a failure lasting 1s and not for the mechanical resistance of copper. The calculation proves that such value can be maintained up to a 500 mm CL distance between the supports.	
300	20	40		
350	20	40		
400	20	40		
450	20	40		
500	20	40		
550	19	38	Values extrapolated by calculation. NB All values in the table, also test values, are valid for any number of supports (calculations according to standard EN 60865-1).	

20 x 5 (mm) copper bars - In 320 A





wöhner



60 mm system

15 x 5 (mm) copper bars - In 250 A

Bar part number: 01 619

Support part number: 01 495


Support CL distance (mm)	I _{cw} (kA for 1s)	I _{pk} (kA)
--------------------------	-----------------------------	----------------------

200	15	30
250	15	30
300	15	30
350	15	30
400	15	30
450	15	30
500	15	30
550	13	26

All values were extrapolated through calculation from the values of the 20x5 tested system and are valid for any number of supports (calculations according to standard EN 60865-1).

NOTE: The I_{cw} value of 15 kA is the limit value calculated for the thermal effects of a failure lasting 1s and not for the mechanical resistance of copper. The calculation proves that such value can be maintained up to a 500 mm CL distance between the supports.

15 x 5 (mm) copper bars - In 250 A





wöhner

60 mm system

eta

12 x 5 (mm) copper bars - In 200 A

Bar part number: 01 618


Support part number: 01 495

Support CL distance (mm)	I _{cw} (kA for 1s)	I _{pk} (kA)
200	12	24
250	12	24
300	12	24
350	12	24
400	12	24
450	12	24
500	12	24
550	12	24

All values were extrapolated through calculation from the values of the 20x5 tested system and are valid for any number of supports (calculations according to standard EN 60865-1).

NOTE: The I_{cw} value of 12 kA is the limit value calculated for the thermal effects of a failure lasting 1s and not for the mechanical resistance of copper. The calculation proves that such value can be maintained up to a 550 mm CL distance between the supports

12 x 5 (mm) copper bars - In 200 A





wöhner

eta

Part 3) CESI test report No A4/519182 (9 pages)

Client Wohner Italia S.r.l. – Milano (Italy)

Tested equipment Bar system for low-voltage switchgear and controlgear assembly

Tests carried out Verification of the short-circuit withstand strength of the main circuits
Verification of the effectiveness of the protective circuit:
- verification of the short-circuit withstand strength of the protective circuit

Standards/Specifications Client's requests based on CEI EN 60439-1 (2000-11) Standard

Test date from August 2, 2004 to August 2, 2004

The results reported in this document relate only to the tested equipment.
Partial reproduction of this document is permitted only with the written permission from CESI.

No. of pages 14 **No. of pages annexed** 5

Issue date November 11, 2004

Prepared BU PeC/TEST - C. Del Giorgio

Verified BU PeC/TEST - A. Elli

Approved BU PeC/TEST P. M. de Nigris

CESI
CENTRO ELETTROTECNICO SPERIMENTALE ITALIANO
Business Unit
Prove e Componenti
Il Responsabile del Laboratorio

Tests witnessed by

Mr. C. Cortese
Mr. G. Nava
Mr. D. Masciardi
Mr. F. Salni

Wohner Italia
ETA
ETA
Brianza Progetti

Identification of the object effected

The Manufacturer guarantees that the tested object is manufactured according to the submitted drawings. CESI checked that these drawings adequately represent in shape and dimensions the essential details and the parts of the tested object.
These drawings, identified by CESI and numbered **A4/510743 No. 1 to 10**, have been returned to the Client.

Only for laboratory requirement, in order to reproduce the test conditions, all the laboratory data are contained in the document marked: MP-A4/509340

The measurement uncertainties of the test results reported in this document comply with the following limits:

voltage : $\pm 5\%$; current : $\pm 5\%$; time : $\pm 5\%$

The measurement uncertainties are estimated at the level of twice the standard deviation (corresponding, in the case of normal distribution, to a confidence level of about 95 %) and have to be considered as maximum estimated values referred to that type of measurement.

Laboratory information**Receipt date of the sample**

July 21, 2004

Test location

CESI – Via Rubattino 54 – Milan

Activity code

44299J

Contents	Page	Test date
Rated characteristics of the tested object assigned by the Client	4	---
Verification of the short-circuit withstand strength of the main circuits - Test arrangements and test procedure	5	---
Connection points for short-circuit tests - Test configuration M8000	6	---
Short-circuit tests results with three-phase current	7	August 2, 2004
Verification of the effectiveness of the protective circuit	8	---
- Short-circuit tests results with single-phase current	9	August 2, 2004
Test circuits M0007 – M0008	10 ÷ 11	---
Photographs of the test object	12 ÷ 14	---
Pages annexed:		
- Oscillograms from test report A4/509340 (total pages:5)		
Reference documents:		
- Drawings identified by CESI and numbered A4/510743 No. 1 to 10		

Rated characteristics of the tested object assigned by the Client

Manufacturer of the bar system	Wohner Italia
Manufacturer of the carpentry	ETA
Operational voltage (Ue)	690 V
Insulation voltage (Ui)	690 V
Frequency	50 Hz

Designation	60 mm system; 320 A
Section of bars	(20x5) mm ²
Rated current	320 A
Short-time withstand current (Icw) and peak withstand current (Ipk)	20 kA for 1 s – 41 kA

Designation	60 mm system; 630 A
Section of bars	(30x10) mm ²
Rated current	630 A
Short-time withstand current (Icw) and peak withstand current (Ipk)	30 kA for 1 s – 63 kA

Designation	60 mm system; 1600/1250 A
Section of double T bars	(720)/(485) mm ²
Rated current	1600/1250 A
Short-time withstand current (Icw) and peak withstand current (Ipk)	50 kA for 1 s – 105 kA

Designation	60 mm system; 2500 A
Section of triple T bars	(1140) mm ²
Rated current	2500 A
Short-time withstand current (Icw) and peak withstand current (Ipk)	50 kA for 1 s – 105 kA
Short-time withstand current (Icw) and peak withstand current (Ipk) of the protective circuit	40 kA for 1 s – 84 kA
Section of the earthing bar	(80x5) mm ²

Verification of the short-circuit withstand strength of the main circuits**Test arrangements and test procedure**


The equipment under test was blocked to the floor of the test room as in normal use and appropriately insulated from earth.

All parts of the equipment intended to be connected to the protective conductor in service, including the enclosure, were connected to the neutral point of supply through a fault current detection device consisting of a fuse of copper wire (of 0,8 mm diameter and about 50 mm in length) connected in series with a resistor, in order to limit the prospective fault current to about 1500 A.

The three-phase tests were performed supplying the terminals of the incoming circuit (point "A" of the test configuration M8000) by one copper tube per-phase having a cross-sectional area of 700 mm²; these conductors were firmly blocked together at a distance of about 30 cm from the incoming terminals of the equipment under test.

Connection points for short-circuit tests

Test configuration M8000



Short-circuit tests results with three-phase current

Test circuit: M0007
Test configuration: M8000
Reference number of the oscillograms: A4/509340

Date: August 2, 2004

Test	Test configuration		Bar system under test	Type of test	Oscillogram	Test current			I ² t	Duration	Frequency		Notes
	supply	short-circuit				Peak value	r.m.s. value	Average value					
No.	point	point	-	-	No./sheets	A	A	A	MA ² s	s	Hz		(*)
1	A	B	630	dynamic/-thermal	4/1	66070	30520 30780 30650	30650	-	1,0	50		a b c
2	A	B	1600/1250A	dynamic/-thermal	7/1	105520	49990 51810 50560	50790	-	1,0	50		a b c
3	A	B	2500A	dynamic/-thermal	10/1	105530	49520 50560 49920	50000	-	1,0	50		a b c
5	A	B	320A	dynamic/-thermal	13/1	42840	19880 20200 19980	20020	-	1,0	50		a b c

Conditions of the assembly after the tests: see notes

(*) Notes: a = the fault current detection device did not melt
b = the bars and the enclosure did not show any deformation
c = the insulation of the conductors and the supporting insulating parts did not show any significant sign of deterioration

Verification of the effectiveness of the protective circuit

Verification of the short-circuit strength of the protective circuit

- Test arrangements and test procedure

The equipment under test was blocked to the floor of the test room as in normal use and appropriately insulated from earth.

The tests were performed connecting a single-phase test supply between the incoming terminal of one phase and the terminal for the incoming protective conductor (points "A" and "T" of the test configuration M8000).

The short-circuit connection between one phase of the main circuits and the protective circuit was made by a copper bar bolted between the lower end of the distribution busbar and the end of the protective conductor (points "H" and "K").

